




Compare the Performance . . .
. . . Measure the Difference

OptiPure QT & FX System Sizing Guide *Ice Machines (cube ice)*

It is common for ice machine manufacturers to size equipment in food service applications to operate approximately 18 hours per day. Recommendations are based on providing the most cost effective and efficient method of delivering the amount of ice needed daily while meeting high demand periods such as lunch and dinner.

The same logic applies when selecting the right water treatment system. NSF Certified capacities of the recommended OptiPure systems meet or exceed ice machine water usage requirements over a six-month period. System flow rates exceed manufacturers required flow rate for proper operation of equipment.



OptiPure filtration systems for ice machines contain IsoNet scale and corrosion technology. IsoNet isolates and evenly distributes media through the core of the filter. This maximizes media contact time with water and provides consistent dosing over a six-month period between filter changes.

* FXI-22, FX+ and QT+ models include 20" sediment prefilters for water supplies with high levels of silt/sediment.



QTCI models are NSF Certified for Cyst and Turbidity reduction.

		Ice Production** 24 hrs. @ 90/70°	Water Usage 6-months @ 50% run-time per day	Water Usage 6-months @ 75% run-time per day
FXI-11	QTI-1 QTCI-1	250	4,500	6,750
		400	7,200	10,800
		550	9,900	14,850
FXI-12 *FXI-22		650	11,700	17,550
		800	14,400	21,600
		950	17,100	25,650
FXI-22P *FXI-22P+	QTI-2 *QTI-2+ QTCI-2 *QTCI-2+	1,000	18,000	27,000
		1,250	22,500	33,750
		1,400	25,200	37,800
		1,600	28,800	43,200
		1,800	32,400	48,600
		2,000	36,000	54,000

**Ice production over a 24 hour period is based on water usage of 20 gal. per 100 pounds.